

รายการทดสอบ	ผลการทดสอบ	ค่ามาตรฐาน	หน่วย	LOD	วิธีทดสอบอ้างอิง
PARASITIC EGGS *	Not Found	< 1	eggs/L	-	SIMPLE-CENTRIFUGAL SEDIMENTATION,FORMALIN-ETHYL ACETATE SEDIMENTATION AND FLOATATION METHOD SIMPLE-CENTRIFUGAL SEDIMENTATION,FORMALIN-ETHYL ACETATE SEDIMENTATION AND FLOATATION METHOD
Coliforms *	<1.8	≤ 5,000	MPN/100mL	-	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA, WEF,24th Edition,2023.Part 9221B.
<i>Escherichia coli</i> *	<1.8	< 1,000	MPN/100mL	-	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA, WEF,24th Edition,2023.Part 9221F.
Fecal Coliforms *	<1.8	≤ 1,000	MPN/100mL	-	Standard Methods for the Examination of Water and Wastewater.APHA, AWWA, WEF,24th Edition,2023.Part 9221E.
pH	6.86	5.5-9.0	pH unit	-	Standard Methods for the Examination of Water and Wastewater.APHA, AWWA, WEF, 24th Edition, 2023.Part 4500-H+.

( 3.2 ; ตรวจไข่นอนพยาธิทางห้องปฏิบัติการ )